



STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE
04333-0016

JOHN ELIAS BALDACCI
GOVERNOR

DAVID A. COLI
COMMISSIONER

June 9, 2003
Subject: Ellsworth
Project No. 12103.00
PIN. 12103.00
Amendment No. 1

Dear Sir/Ms.:

Please make the following changes to your bid package.

1) In the contract book please make the following changes.

- a.)** In section 01100-“Summary of Work” Subsection 1.3 “Work Covered by Contract Documents”, please add the following as sentence # 2 to paragraph A. “Project Identification:” “Additionally, the project shall consist of replacement of the existing boiler room ceiling in its entirety, complete with support framing for upgrade to a one hour fire rating.”
- b.)** In Section 01731-“Cutting and Patching” Subsection 1.2 “Summary” Item B. “Related Sections include the following” line 4. a add the following sentence: “Requirements further apply to the replacement of the entire boiler room ceiling assembly as outlined herein.”
- c.)** In Section 13280-“Hazardous Material Remediation”, subsection 3.1 “Work Sequence and Special Instructions for Interior Abatement” Paragraph “A Intention” subparagraph “2” section “c” please delete in its entirety the 2nd and 3rd sentence and replace with the following new sentence which states **“Remove the entire Gypsum ceiling in the Boiler room.”**

Make these changes in pen and ink.

2) Make the following changes to the plan sheets.

- a.)** On Plan Sheet H-100 Please delete in its entirety notes # 1 and 2 and replace with the following new note which states: “Remove the entire Gypsum ceiling in the Boiler room. The framing above may remain in place for demolition.”



PRINTED ON RECYCLED PAPER

b.) On Plan Sheet M-100 Plan Part A6 DELETE the PRV and Double Check Backflow Preventer at the domestic cold water supply serving the tankless coil at the new boiler. These are required only at the domestic water make-up to the boiler, as outlined elsewhere.

c.) On Plan Sheet M-100 Plan Part A6 In the General Notes add the following to note # 2 the 3rd sentence after the word "size" add "(3/4)". In the 4th sentence after the word "upstream" add the words "**and downstream**".

d.) On Plan Sheet M-100 Plan Part A6 In the General Notes add the following to note # 5 in the 2nd sentence after the word "complete" add "**and turn it over to the owner**".

Make these changes in pen and ink.

3) Please add the attached one page plan sheet numbered "**SKS-01**"

Consider these changes prior to submitting your bid on June 11, 2003.

Sincerely,

A handwritten signature in cursive script that reads "Bruce R. Carter".

Bruce R. Carter
Contracts Engineer

